

TOWN OF GORHAM, NEW HAMPSHIRE

MINUTES: Water & Sewer Commission Meeting

DATE: 8 February 2021 TIME: 4:00 PM


PRESENT: Jeff Tennis, Lee Carroll, and Ted Miller

- Roger Goulet unable to attend meeting. He is out recouping from his surgery.
- Reviewed meeting minutes of 25 January 2021 Water and Sewer Commission Meeting and signed same.
- Reviewed invoices and signed same.
- **Reviewed and signed Supplemental Water & Sewer Commitment** of 5 February 2021 in the amount of \$61.46. Signed same.
- **Reviewed and signed Water Capital Reserve payment** to EII in the amount of \$2,769.00 for Water Treatment Plant valve operator.
- **Reviewed NHDES Disinfection By Products Report** and signed same. No issues.
- **Reviewed Water& Sewer Capital Reserve Accounts** status through January 2021.
- **Reviewed Water & Sewer Expenditures** through January. No issues.
- **Reviewed Water & Sewer Rents & other income** through January. Normal for this time of year.
- **Reviewed draft letter to Jason Hunter** regarding possible new brewery connection to sewer system. Several edits recommended before release. Commissioners will review new draft at their next meeting.
- **Well #2 Generator** surged again during shut down. Service tech may get here later this week to check.
- **Town Budget Hearing** is Wednesday at 6:30 PM at the Gorham Middle High School Gym.
- **Filter #2 was cleaned** (routine) last week. Hope to do Filter #1 next week.
- **New valve actuator at WFP** installed and now working fine.
- **New flow meter on Gorham Hill** installed late February. Awaiting EII to come and do connections electrically.
- **No air handler coil for WWTF** received and installed. Now in operation.
- There was no non-public session at this meeting.
- The next Commission Meeting is Monday, 22 February 2021 at 4:00 PM.
- Meeting adjourned at 5:00 PM.

Roger G. Goulet, Commissioner



Theodore A. Miller, Commissioner



Lee F. Carroll, Commissioner